

Concord Express Installation Addendum

Introduction

This is the Concord Express Installation Addendum (466-1776B) for the UTC Concord Express Installation Instructions (466-1665). This document includes late-breaking information on this product that did not make it into the manual. Where information differs between the two documents, this document supersedes the manual.

This panel has been factory programmed to ADT specifications. Table 1 below lists the UTC factory defaults and their ADT equivalents.

Table 1: UTC and ADT default settings

Parameter	UTC default	ADT default	Notes
Installer code	4321	6321	
Quick arm	Off	On	
Keyswitch arming	Off	Off	
Backup	On	Off	All CS phone numbers
CID/SIA reporting	CID	CID	
Latchkey reports	On	Off	All phone numbers
Phone test frequency	7	255	
Next phone test	7	255	
RF Tx timeout	12 hours	24 hours	
Activity timeout	24 hours	42 hours	
Entry delay	32 seconds	48 seconds	
Exit delay	64 seconds	96 seconds	
Extended delay	4 minutes	2 minutes	
Back in service	On	Off	
Zone restorals	Off	On	
Immediate beeps	Off	On	
Global fire	Off	On	
Dialer abort delay	30	15	
TP panic RPT FMT	Off	On	

Note: Group 21 characteristics have been changed to No restoral, not supervised.

Copyright © 2012 UTC Fire & Security Americas Corporation, Inc.

Interlogix is part of UTC Climate Controls & Security, a unit of United Technologies Corporation. All rights reserved.